



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	6200-2362:0001
CATEGORY:	6200 - EXIT SIGNS
LISTEE:	Ertecnica LDA-Everlux EN 109-Araujos, , CA, Contact: JACINTO, RENATA 908 264 4041 Email: renata-jacinto@everlux.com
DESIGN:	<p>Models C0011T40241ULCA, C0012T40241ULCA, C0013T40241ULCA, C0014T40241ULCA, C0015T40241ULCA and C0016T40241ULCA Photoluminescent Exit Signs.</p> <p>Models C0021T50241ULCA, C0022T50241ULCA, C0023T50241ULCA, C0024T50241ULCA, C0025T50241ULCA and C0026T50241ULCA Photoluminescent Sortie Signs.</p> <p>Models C0001T40241ULCA, C0002T40241ULCA, C0003T40241ULCA, C0053T20201ULCA and C0054T20201ULCA Photoluminescent Running Man Signs.</p> <p>These signs are manufactured with a strong 1mm thick aluminum base coated with a photoluminescent pigment of high luminous intensity. The sign features an antistatic and easy to clean surface protected with a transparent film.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
RATING:	Maximum viewing distance 50 ft.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Authority having jurisdiction should be consulted prior to installation.
MARKING:	Listee's name, model number, activating light type and minimum illuminance level, legible viewing distance, and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:	Listed as photo-luminescent exit signs for use where permitted by code and only in locations where a minimum 5 foot candles of external unfiltered approved illumination source is present on the sign face, is deemed reliable and is supplied by a circuit not controlled by automatic timers or sensors, and whose controls are accessible only to authorized personnel. This reliable external illumination source is to be energized at all times of building occupancy. For indoor use only. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in UL 924, 10th Edition.
NOTES:	

1-9-23 DAL



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/15/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division