



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	6210-2362:0002
<b>CATEGORY:</b>	6210 - EXIT PATH MARKING
<b>LISTEE:</b>	Ertecnica LDA-Everlux EN 109-Araujos, , CA, Contact: JACINTO, RENATA 908 264 4041 Email: renata-jacinto@everlux.com
<b>DESIGN:</b>	<p>Models C7101T12021ULCA, C7101T12031ULCA, C7101F12051ULCA, C7102T12021ULCA, C7102T12031ULCA, C7102T12051ULCA, C7103T12021ULCA, C7103T12031ULCA, C7103T12051ULCA, C7131F12021ULCA, C7131F12031ULCA, C7131F12051ULCA, C7132F12021ULCA, C7132F12031ULCA, C7132F12051ULCA, C7133F12021ULCA, C7133F12031ULCA, C7133F12051ULCA, C7134F12021ULCA, C7134F12031ULCA, C7134F12051ULCA, C7161F27181ULCA, C3151Z10161ULCA, C3151Z10271ULCA, C3151Z10351ULCA, C3151Z10501ULCA, C3155Z10161ULCA, C3155Z10271ULCA, C3155Z10351ULCA, C3155Z10501ULCA, L0151T15151ULCA, L0151T20201ULCA, L0152T15151ULCA, L0152T20201ULCA, L0153T15151ULCA, L0153T20201ULCA, L0154T15151ULCA, L0154T20201ULCA, L0161T30151ULCA, L0162T30151ULCA, L0163T30151ULCA, L0164T30151ULCA, L0165T30151ULCA, L0166T30151ULCA, L0167T30151ULCA, L0168T30151ULCA, L0169T30151ULCA, L0170T30151ULCA, L0181T30151ULCA, L0182T30151ULCA, L0191T42241ULCA, L0192T42241ULCA, L0193T40241ULCA, L0194T42241ULCA, L0195T42241ULCA, L0196T42241ULCA, L0201T20401ULCA, L0202T20401ULCA, L0203T20401ULCA, L0204T20401ULCA, L0205T20301ULCA, L0206T20301ULCA, L0207T20301ULCA, L0208T20301ULCA, L0401T12301ULCA, L0402T12301ULCA, L0421T30151ULCA, L0421T40201ULCA, L0421T60301ULCA, L0431T15201ULCA, L0432T15201ULCA, L0451T20301ULCA, L0461T40601ULCA, L7181F00101ULCA, L0327F00101ULCA, L0325F27181ULCA, L0331Z10161ULCA, L0331Z10271ULCA, L0331Z10351ULCA, L0331Z10501ULCA, L0332Z10161ULCA, L0332Z10271ULCA, L0332Z10351ULCA, L0332Z10501ULCA, C0181T30151ULCA, C0182T40151ULCA, C0191T42241ULCA, C0192T42241ULCA, C0193T42241ULCA, C0194T42241ULCA, C0195T42241ULCA, C0196T42241ULCA, C0201T30401ULCA, C0202T30401ULCA, C0203T30401ULCA, C0204T30401ULCA, C0205T30301ULCA, C0206T30301ULCA, C0207T30301ULCA, C0208T30301ULCA, C0421T30151ULCA, C0421T40201ULCA, C0421T60301ULCA, C0431T15201ULCA, C0432T15201ULCA, C0451T20301ULCA, and C0461T40601ULCA Photoluminescent Floor Proximity Egress Path Marking Systems. Photoluminescent self-adhesive plastic, 0.39mm thickness, protected by a non-slip laminated layer with 0.81mm thickness.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
<b>RATING:</b>	N/A



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction. Authority having jurisdiction should be consulted prior to installation.
<b>MARKING:</b>	Listee's name, model number, and UL label.
<b>APPROVAL:</b>	Listed as photo-luminescent exit signs for use where permitted by code and only in locations where a minimum 1 foot candles of external unfiltered approved illumination source is present on the sign face, is deemed reliable and is supplied by a circuit not controlled by automatic timers or sensors, and whose controls are accessible only to authorized personnel. This reliable external illumination source is to be energized at all times of building occupancy. For indoor use only. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in UL 1994, 4th Edition.
<b>NOTES:</b>	

1-9-23 DAL



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/15/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division